

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7315-1491:106 Page 1 of 1

CATEGORY: Power Supply

LISTEE: Vision Systems Inc., 35 Pond Park Road, Hingham, MA 02043
Contact: *Wes Marcks (781) 740-2223 Fax (781) 740-4433

DESIGN: Model VPS-100US Power Supply and Model VBC-001 Battery Expansion Cabinet. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 27.6 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
Unit must provide the required 24 hr. back-up.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a power supply and battery cabinet for use with listee's separately listed VESDA LaserPLUS detectors.

*Rev. 0618-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 18, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager